

Certificate of Compliance

Certificate Number 20090910-R9700
Report Reference 2009 September 10
Issue Date 2009 September 10

Page 1 of 1



Issued to: **3M Company**

3M Center
St Paul, MN 55144


This is to certify that representative samples of **Batts and Blankets**

Have been investigated by Underwriters Laboratories Inc.® (UL) or any authorized licensee of UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: ISO 6944-1985, "Fire Resistance Tests - Ventilation Ducts."

Additional Information: 3M FireBarrier Duct Wrap 615+ for use in Ventilation System
Nos. V-20 and V-27.
3M FireBarrier Duct Wrap 615+ Collar for use in Ventilation System
Nos. V-20 and V-27.

Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.


Look for the UL Classification Mark on the product

Issued by:


Mona Couloute

Underwriters Laboratories Inc.

Reviewed by:


Steven Hoffman

Underwriters Laboratories Inc.