



NOTES:

1. SEE CURRENT CATALOG FOR ADDITIONAL PART SUFFIXES TO INDICATE PACKAGE QUANTITY.
2. THE FIBER-DUCT 2x2, 4x4 AND FIBERRUNNER 2x2 UNDER-FLOOR SUPPORT BRACKET IS USED TO SUPPORT THE FIBER-DUCT 2x2, 4x4 AND FIBERRUNNER 2x2 CABLE ROUTING SYSTEMS FROM 1" (25.4) DIAMETER OR 7/8" (22.2) SQUARE TUBE FLOOR PEDESTALS.
3. THE FIBER-DUCT 2x2, 4x4 AND FIBERRUNNER 2x2 UNDER-FLOOR SUPPORT BRACKET INCLUDES:
 ONE (1) BRACKET,
 TWO (2) 1/4-20x2x1 1/8x1 ROUND BEND U-BOLTS (FUSB ONLY),
 TWO (2) M6x1x50x28.6x24.6 ROUND BEND U-BOLTS (FUSBM ONLY),
 TWO (2) 1/4-20 HEX NUTS (FUSB ONLY),
 TWO (2) M6x1 (FUSBM ONLY),
 TWO (2) 1/4 HELICAL SPRING LOCKWASHERS (FUSB ONLY),
 TWO (2) M6 LOCKWASHERS (FUSBM ONLY),
 TWO (2) #10-32x1/2 PAN HEAD SLOTTED MACHINE SCREWS,
 TWO (2) #10 HELICAL SPRING LOCKWASHERS,
 TWO (2) #10-32 HEX MACHINE SCREW NUTS.
4. FINISH COLOR: YELLOW ZINC DICHROMATE (EXCEPT FOR HARDWARE)
5. DIMENSIONS IN PARENTHESES ARE IN METRIC.

| | |
|---------------------|-----------------------------|
| PANDUIT PART NUMBER | WEIGHT |
| FUSB FUSBM | 1.20 LB/EACH (543g/EACH) |



ENG. REF.: D35245BQ_DC_FUSB_03.prt

CAD FILENAME/LAYERS: G FUSB.pdf

PANDUIT CORP TINLEY PARK, ILLINOIS
 FIBER-DUCT 2x2, 4x4 AND FIBERRUNNER 2x2
 UNDER-FLOOR SUPPORT BRACKET
 (FUSB, FUSBM)
 CUSTOMER DRAWING

UNLESS OTHERWISE SPECIFIED, DIMENSIONAL TOLERANCES ARE:
 (.X) ± (.XXX) ±
 (.XX) ± .03 (.8) ANGLES ±

UNLESS OTHERWISE SPECIFIED, ALL DIMENSIONS ARE GIVEN IN INCHES, THIRD ANGLE PROJECTION.

DRAWN BY: TPC
 DATE: 11-18-96
 CHECK'D: CEF

MAT'L: STEEL

SCALE: NONE

DRAWING NO.: 35245-17
 DWG SIZE: A

| REV | DATE | BY | CHK | DESCRIPTION | ECN | R | CUST | SUP | GMBH |
|-----|----------|-----|-----|-----------------------------------------------------|----------|----|------|-----|------|
| - | ----- | --- | --- | J. REVISED MATERIAL I. REVISED PART WEIGHT | ----- | -- | -- | | |
| - | ----- | --- | --- | H. REVISED GENERAL NOTES G. REVISED CAD FILENAME | ----- | -- | -- | | |
| 3 | 12-28-06 | MSO | RN | F. REVISED DRAWING TITLE E. REVISED AND REDRAWN | 35245-17 | RN | RN | | |